

ORDINANCE NO. 1997-677

AN ORDINANCE AMENDING CHAPTER 9, ARTICLE 9, SECTION 9-901 OF THE MUNICIPAL CODE OF GOTHENBURG, NEBRASKA, REPEALING ALL ORDINANCES OR PARTS OF ORDINANCES IN CONFLICT HEREWITH AND PROVIDING FOR AN EFFECTIVE DATE.

BE IT ORDAINED BY THE MAYOR AND CITY COUNCIL OF THE CITY OF GOTHENBURG, DAWSON COUNTY, NEBRASKA AS FOLLOWS:

Section 1. A copy of Chapter 9, Article 9, Section 9-901, of the Municipal Code of Gothenburg, Nebraska is attached hereto marked as Exhibit "A" and incorporated herein by this reference as though fully set forth.

Section 2. That Chapter 9, Article 8, Section 9-801, of the Municipal Code of Gothenburg, Nebraska, be amended to read as follows:

9-901 ELECTRICAL CODE: ADOPTED BY REFERENCE; ADDITIONAL REQUIREMENTS.

(1) To provide certain minimum standards, provisions, and requirements for safe and fire proof installation, methods of connection, and uses of materials in the installation of electrical wiring and appliances, the National Electric Code, 1996 Edition, as recommended and published by the National Fire Protection Association, and printed in book or pamphlet form is hereby incorporated by reference in addition to all amended editions as though printed in full herein insofar as said code does not conflict with the Statutes of the State of Nebraska. One (1) copy of the Electrical Code is on file at the office of the Municipal Clerk and is available for public inspection at any reasonable time. Except as hereafter provided, the Electrical Code shall be controlling throughout the Municipality and throughout its zoning jurisdiction.

(2) In addition to the standards set forth in subsection (1) of this section, the following requirements are hereby adopted throughout the Municipality and its zoning jurisdiction:

- (a) All electrical meters shall be installed at a height of between sixty (60") inches and seventy-two (72") inches from the ground level.
- (b) All electrical meters shall be grounded with an eight (8') foot copper rod of at least one-half (1/2") inch diameter. All ground wire leading to such rod shall be placed in conduit or PVC pipe.
- (c) All underground services shall have rigid conduit above ground to the main connection.
- (d) All underground services coming from a meter box shall be provided with an overload protection device in accordance with the standards adopted by the electrical inspection and licensing division, which device shall be placed on the service between the meter box and the ground level.
- (e) All main service roof mast shall be constructed of rigid galvanized conduit with a minimum diameter of two (2") inches.
- (f) All wiring shall be placed in conduit in buildings;  
(1) a portion of which is exclusively used for retail, wholesale or business purposes, and does not constitute an out building, garage or shed on a residential lot, (2) which have a seating capacity, including temporary seating, in any one (1) room in excess of fifty (50) persons.


(Ref. 17-1001, 18-132, 19-902, 19-922 RS Neb.)

Section 3. That any ordinance or section passed and approved prior to the passage, approval, and publication or posting of this ordinance and in conflict with it provisions, is hereby repealed.


Section 4. This ordinance shall take effect and be in full force from and after its passage, approval, and publication or posting as required by law.

Passed and approved this 15<sup>TH</sup> day of June, 1997.


CITY OF GOTHENBURG, DAWSON  
COUNTY, NEBRASKA

BY   
Richard E. Blase, Mayor

ATTEST:

  
\_\_\_\_\_  
Connie Stull, City Clerk

APPROVED AS TO FORM:

  
\_\_\_\_\_  
Michael L. Bacon  
City Attorney